


# REPORT

## TRUESDAIL LABORATORIES, INC.



CHEMISTS - MICROBIOLOGISTS - ENGINEERS  
RESEARCH - DEVELOPMENT - TESTING

14201 FRANKLIN AVENUE  
TUSTIN, CALIFORNIA 92680  
AREA CODE 714 • 730-6239  
AREA CODE 213 • 225-1564  
CABLE: TRUELABS

CLIENT Douglas Aircraft Company  
Internal Mail Code 211-40  
3855 Lakewood Blvd.  
Long Beach, CA 90846  
Attention: Robert M. Tomko

SAMPLE Storm drain inspection - monthly (January)  
P.O. #T&M 23465 C

DATE February 2, 1988  
RECEIVED January 19, 1988  
LABORATORY NO. 23640

### INVESTIGATION

As requested by the CRWQCB for MPDES permit #'s CA0001406 & CA0001414

### RESULTS

A representative of Truesdail Laboratories, Inc. tested the storm drain discharge on January 19, 1988 at the Douglas, Torrance facility and Long Beach facility (003). The discharge was tested for flow rate, pH, and temperature. A grab sample was returned to the laboratory and analyzed according to the American Public Health Association's "Standard Methods," 16th Edition. The results are as follows:


<u>Sample I.D.</u>	<u>Date</u>	<u>Time</u>	<u>Flow - gpd</u>	<u>Temp °F</u>	<u>pH Units</u>
Long Beach (003)	1/19/88	2:20	16,546	62	8.0
Torrance	1/19/88	12:10	550	58	7.0

#### Long Beach 003

Nitrate (353.3)	34
Phosphorus (365.3)	1.2
Sulfate (375.4)	220
Iron (Fe, 236.1)	0.23
Magnesium (Mg, 242.1)	8.8
Zinc (Zn, 289.1)	0.48

Respectfully Submitted,

TRUESDAIL LABORATORIES, INC.

  
Luis Perez, Supervisor  
Industrial Waste

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from these Laboratories.